



IEC SYSTEM FOR CONFORMITY  
TESTING TO STANDARDS FOR  
SAFETY OF ELECTRICAL  
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-9340

## CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2005-07-07

Product: Auxiliary switch

Applicant: LS Industrial systems Co., Ltd.. 1, Songjeong-dong, Huengdeok-gu, Cheongju-si, Chungcheongbuk-do, 361-720 Korea, Republic Of

Manufacturer: LS Industrial systems Co., Ltd.. 1, Songjeong-dong, Huengdeok-gu, Cheongju-si, Chungcheongbuk-do, 361-720 Korea, Republic Of

Factory: LS Industrial systems Co., Ltd.. 1, Songjeong-dong, Huengdeok-gu, Cheongju-si, Chungcheongbuk-do, 361-720 Korea, Republic Of

Rating and principal characteristics: Ue 600 V, Uimp = 8 kV, Ith = 16 A  
Ratings: See Annex and test report 2077896.55

Trade mark (if any): Meta-MEC, LSIS, GMC

Model/Type reference: AU-100

Additional information:

Sample of product tested to be in conformity with IEC: 60947-5-1(ed.2);am1;am2

Test Report Ref. No: 2077896.55

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

Signed by: H.H.M. Versteegen

Date of issue: 2005-07-07

**KEMA**



Annex to CB test certificate No. NL-9340.doc

**Product data:**

Product	:	Auxiliary switch
Trade name:	:	Meta-MEC, LSIS, GMC
Type	:	AU-100
Contacts	:	1 NO, 1 NC contact
Rated impulse voltage (Uimp)	:	8 kV
Conventional free air thermal current (Ith)	:	16 A
Ratings	:	AC-15
		120 V ac 240 V ac 480 V ac 600 V ac
		6 A 5 A 3 A 3 A
Rated conditional short circuit current	:	1 kA
Rating of SCPD	:	MMS-32H 17A