



CERTIFICATE FI 26604

Our Ref. 260942-2

Product Multiway terminal block
Type PA16, PA18
Trade mark Heavy Power
Certificate Holder/Manufacturer Heavy Power Co. Ltd.
 No. 7, Lane 106, WuKung 3rd Road
 Wuku Industrial Park, TAIPEI HSIEN
 TAIWAN
Technical information Type PA16: 16 mm², 500 V, T85 or T110
 Type PA18: 25 mm², 500 V, T85 or T110
Other information T85 Housing material Polypropylene (PP)
 T110 Housing material Nylon

The product is certified according to the following standard(s) EN 60998-2-1:2004

Validity This certificate is valid until 21 January 2016 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue 21 January 2011

Signature **SGS Fimko Ltd**


 Sixten Lökfors
 Project Manager



This certificate has 1 appendix

SGS



This certificate is issued by the company under its General Conditions for Certification Services accessible at www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



Appendix to Certificate: 26604

Manufacturing site

Heavy Power Co., Ltd.
Hsiao Tung Pao, Chu Shan Fu Chen
DONGGUAN CITY, 523120
CHINA

Additional information

The product has CB certificates FI 3206 and 3207 issued by SGS Fimko Ltd in accordance with the CB-system.

This certificate replaces previous FI Certificate no. 21763 A1 dated 17 October 2008, due to new testing.