



Test Report issued under the responsibility of:

Intertek

**TEST REPORT
IEC 61010-031**

**Safety requirements for electrical equipment for measurement, control,
and laboratory use**

**Part -031: Safety requirements for hand-held probe assemblies for
electrical measurement and test**

Report Reference No......: GZ11051010-1

Date of issue.....: 27 May 2011

Total number of pages..... 31

CB Testing Laboratory.....: Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Address.....: Block E, No.7-2 Guang Dong Software Science Park, Caipin Road,
Guangzhou Science City, GETDD, Guangzhou, China

Applicant's name.....: Precision Mastech Enterprises(Hong Kong) Limited
Address.....: Unit 1901, Yen Sheng Centre, 64 Hoi Yuen Road, Kwun Tong,
Kowloon, Hong Kong

Test specification:

Standard: EN 61010-31:2002 (First Edition) + Amd 1:2008

Test procedure: LVD

Non-standard test method.....: N/A

Test Report Form No......: IEC 61010_031C

Test Report Form(s) Originator: KTL (Korea Testing Laboratory)

Master TRF.....: 2008-08

Copyright © 2008 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.



Test item description : Test Lead


Trade Mark: Mastech

Manufacturer.....: Precision Mastech Enterprises(Hong Kong) Limited

Model/Type reference.....: T3030C

Ratings.....: 1000 V CAT III 600 V CAT IV, MAX.10 A

| | |
|--|--|
| Testing procedure and testing location: | |
| <input checked="" type="checkbox"/> CB Testing Laboratory: Testing location/ address : | Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China |
| <input type="checkbox"/> Associated CB Test Laboratory: Testing location/ address : | |
| Tested by (name + signature) : Raymond Yin |  |
| Approved by (+ signature) : Justin He |  |
| <input type="checkbox"/> Testing procedure: TMP Tested by (name + signature) : Approved by (+ signature) : Testing location/ address : | |
| <input type="checkbox"/> Testing procedure: WMT Tested by (name + signature) : Witnessed by (+ signature) : Approved by (+ signature) : Testing location/ address : | |
| <input type="checkbox"/> Testing procedure: SMT Tested by (name + signature) : Approved by (+ signature) : Supervised by (+ signature) : Testing location/ address : | |
| <input type="checkbox"/> Testing procedure: RMT Tested by (name + signature) : Approved by (+ signature) : Supervised by (+ signature) : Testing location/ address : | |


| | |
|--|--|
| Summary of testing: | |
| Tests performed (name of test and test clause): All applicable test items | Testing location: Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China |
| Summary of compliance with National Differences: None | |
| Copy of marking plate The following Markings are molded in the probe body: <div style="display: flex; justify-content: space-around; align-items: center;">  </div> | |

| | |
|--|---|
| Test item particulars : | |
| Type of item tested | Measurement |
| Description of equipment function | The unit is only test probe for measurement |
| Classification | Type A |
| Protection class..... | II |
| Measurement category | III, IV |
| POLLUTION DEGREE | 2 |
| Environmental rating..... | standard |
| Operating conditions..... | continuous |
| Overall size of the equipment (W x D x H) | 1220 mm |
| Mass of the equipment (kg) | 0.075 |
| Marked degree of protection to IEC 60529 | Ordinary equipment |
| Possible test case verdicts: | |
| - test case does not apply to the test object..... | N/A |
| - test object does meet the requirement | P (Pass) |
| - test object does not meet the requirement | F (Fail) |
| Testing : | |
| Date of receipt of test item..... | 18 May 2011 |
| Date (s) of performance of tests | 18 May 2011 – 25 May 2011 |
| General remarks: | |
| <p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.</p> <p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a point is used as the decimal separator.</p> | |

General product information:

The apparatus is a component, it shall be used with relevant measure apparatus.

| | TABLE: 1 - Documents attached to this report | |
|--------------|---|--------------|
| Document No. | Document description | Page Numbers |
| Attachment | Photo | 2 |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

| IEC 61010-031 | | | |
|---------------|---|---|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| 5 | MARKING AND DOCUMENTATION | | P |
| 5.1 | Markings | | P |
| 5.1.1 | Markings applicable for whole probe assembly not located on operator removable parts | Markings molded in the probe body | P |
| | Letter symbols (IEC 60027) used | | P |
| | Graphic symbols (Table 1) used; or | Symbol  used | P |
| | if other symbol used; explained in accompanying documentation | | N/A |
| | In case of less space for required markings: | | N/A |
| | - symbol 10 of table 1 used | | N/A |
| | - all necessary information included in documentation | | N/A |
| 5.1.2 | Identification | | P |
| 5.1.2 a) | Name or registered trademark | Mastech | P |
| 5.1.2 b) | For type B and C, also model no. or similar | Type A | N/A |
| | If designed for use with specific model this is made clear and | | N/A |
| | model identified by marking or in documentation | | N/A |
| 5.1.3 | Fuses | No fuse employed | N/A |
| | All details necessary for fuse replacement | | N/A |
| | Includes rated voltage and current breaking capacity | | N/A |
| | If selected according to particular application; marked with symbol 10 and information in documentation | | N/A |
| 5.1.4 | Necessary identification for TERMINALS, connectors etc | | N/A |
| 5.1.6 | Rating | | P |
| | Maximum RATED voltage to earth | 1000V CATIII 600V CATIV | P |
| | (CAT I) Symbol 10 used | | N/A |
| | (CAT II-IV) Category marked | CAT III, CAT IV | P |
| | Nature of voltage (ac, dc etc.) | Applicable to both r.m.s and dc | N/A |
| | Reference connector intended for connection to voltages exceeding the values of 6.3.1.1 | No reference connector | N/A |

| IEC 61010-031 | | | |
|---------------|--|------------------------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| | For type A and type D only, the maximum RATED current unless specified for high impedance inputs | MAX. 10 A molded in the probe body | P |
| 5.2 | Warning markings | | P |
| | Visible when ready for NORMAL USE | | P |
| | If necessary marked with symbol 10 | | P |
| | Near or on particular parts of the PROBE ASSEMBLY | | P |
| | Advise to disconnect or isolate during access to HAZARDOUS LIVE parts or | | N/A |
| | marked with symbol 10 and information in the instruction manual | | N/A |
| | Easily touched heated parts, if not self-evident, marked with symbol 9 | | N/A |
| 5.3 | Durability of markings | | P |
| | The required markings are clear and legible (NORMAL USE) | see Form A.3 | P |
| | Resist cleaning (clear, legible and not worked loose) | | P |
| 5.4 | Documentation | | N/A |
| 5.4.1 | General | | N/A |
| 5.4.1 a) | Technical specification | | N/A |
| 5.4.1 b) | Instructions for use | | N/A |
| 5.4.1 c) | Name and address of manufacturer or supplier | | N/A |
| 5.4.1 d) | The information specified in 5.4.2 to 5.4.4 | | N/A |
| | A clear explanation of warning symbols is in the documentation or | | N/A |
| | Information is durably and legibly marked on the equipment | | N/A |
| | Statement that symbol 10 means documentation needs to be consulted | | N/A |
| 5.4.2 | Ratings | | N/A |
| | Maximum voltage RATING | | N/A |
| | Maximum current RATING | | N/A |
| | Statement of the range of environmental conditions | | N/A |

| IEC 61010-031 | | | |
|---------------|--|---|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| 5.4.3 | Operation | | N/A |
| 5.4.3 a) | Identification of operating controls | | N/A |
| 5.4.3 b) | Interconnection requirements | | N/A |
| | Specification of accessories, materials etc | | N/A |
| 5.4.3 c) | Specification of intermittent operation limits | | N/A |
| 5.4.3 d) | Explanation of required and used symbols | | N/A |
| 5.4.3 e) | Replacement of consumables | | N/A |
| 5.4.3 f) | Definition of measurement category (if marked with CAT) | | N/A |
| 5.4.3 g) | If marked CAT I, a warning not to use in other CAT | | N/A |
| 5.4.3 h) | Cleaning if necessary | | N/A |
| 5.4.3 i) | Warning for the lower CAT of a combination of a PROBE ASSEMBLY and an accessory | | N/A |
| | A statement against use in a manner not specified by the manufacturer | | N/A |
| 5.4.4 | Maintenance | | N/A |
| | Sufficient preventive maintenance and inspection for RESPONSIBLE BODY | | N/A |
| | Parts to be supplied or examined by the manufacturer only | | N/A |
| | RATING and characteristics of fuses (see 5.1.3) | | N/A |
| 6 | PROTECTION AGAINST ELECTRIC SHOCK | | P |
| 6.1 | General | see Form A.4 | P |
| 6.1.1 | Exceptions | | P |
| 6.1.1 a) | Parts intended to be replaced by the operator (for example, fuses), but only if they have a warning marking according to 5.2 | | N/A |
| 6.1.1 b) | PROBE TIPS, provided that they meet the requirements of 6.4.4 | Refer to clause 6.4.4 | P |
| 6.2 | Determination of ACCESSIBLE parts | | N/A |
| | According to figure 3 | Obvious to determine the accessible parts | N/A |
| 6.3 | Permissible limits for ACCESSIBLE parts | | P |
| | Measurements performed according to figure 4 | | P |
| 6.3.1 | Values in NORMAL CONDITION | see Form A.6 | P |
| 6.3.2 | Values in SINGLE FAULT CONDITION | see Form A.7 | P |

| IEC 61010-031 | | | |
|---------------|---|-------------------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| 6.4 | Insulation requirements for protection against electric shock | | P |
| 6.4.1 | Connectors | | N/A |
| 6.4.1 a) | Connectors in fully mated position: | No such part | N/A |
| | i) Connecting probe to measuring equipment insulated by at least basic insulation | | N/A |
| | ii) Intended to be HAND-HELD insulated by DOUBLE or REINFORCED INSULATION | | N/A |
| 6.4.1 b) | Connectors in partially mated position: | | N/A |
| | insulated by at least BASIC INSULATION | | N/A |
| | Voltage test with test finger (B.1) | | N/A |
| 6.4.1 c) | Connectors in unmated position: | | N/A |
| | Except for locking or screw-held type connectors or limited current by PROTECTIVE IMPEDANCE: | | N/A |
| | i) HAZARDOUS LIVE parts not ACCESSIBLE | | N/A |
| | Up to 1 kV a.c. or 1.5 kV d.c., not ACCESSIBLE | | N/A |
| | Above 1 kV a.c. or 1.5 kV d.c., voltage test with test finger | | N/A |
| | ii) Stackable connectors | | N/A |
| | HAZARDOUS LIVE parts separated by BASIC INSULATION from ACCESSIBLE parts | | N/A |
| | CLEARANCE and CREEPAGE meet the requirements for BASIC INSULATION | | N/A |
| | Voltage test in acc. to 6.6 | | N/A |
| 6.4.2 | HAND-HELD parts other than connectors | | P |
| | HAZARDOUS LIVE parts separated by DOUBLE or REINFORCED INSULATION from ACCESSIBLE parts | see Form A.4 | P |
| | CLEARANCE and CREEPAGE meet the requirements for DOUBLE or REINFORCED INSULATION | see Form A.9 | P |
| | Voltage test in acc. 6.6 (specify parts) | see Form A.10 | P |
| | REFERENCE CONNECTOR | | N/A |
| 6.4.3 | Cables | | P |
| | RATED for maximum voltage and current | | P |
| | DOUBLE or REINFORCED INSULATION based on voltages (min 125 V/500 V) according to type of PROBE ASSEMBLIES | | N/A |
| | or for maximum RATED voltage | Rated 1000V CATIII 600V CATIV | P |

| IEC 61010-031 | | | |
|---------------|--|----------------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| | Voltage test in acc. 6.6 (specify parts) | see Form A.10 | P |
| 6.4.4 | PROBE TIPS | | P |
| | BARRIER providing safe distance: | | P |
| | - CLEARANCE and CREEPAGE meet the requirements for REINFORCED INSULATION | see Form A.9 | P |
| | Spring-loaded squeeze PROBE ASSEMBLIES: (rated for WORKING VOLTAGE ≤ 1 kV) | No such part | N/A |
| | a) Actuation prevents touching HAZARDOUS LIVE parts | | N/A |
| | b) Additional protective distance of 45 mm longer than for barrier | | N/A |
| | Crocodile clips and similar without barrier: (rated for CAT I or II) | | N/A |
| | - have tactile indication | | N/A |
| 6.4.5 | DOUBLE INSULATION and REINFORCED INSULATION | | P |
| | See 6.5, 6.6 and 6.7.2 | | P |
| 6.4.6 | PROTECTIVE IMPEDANCE | | N/A |
| | Appropriate HIGH-INTEGRITY single component used for protection (see 12.3) | No such component | N/A |
| | Components, wires and connections are suitably RATED even for SINGLE FAULT CONDITION | | N/A |
| 6.5 | CLEARANCES AND CREEPAGE DISTANCES | | P |
| | CLEARANCES and CREEPAGE DISTANCES between circuits and parts | see Form A.4 and Form A.9 | P |
| 6.6 | Voltage tests | | P |
| | Humidity pre-conditioning (6.6.2) conducted | | P |
| | Test voltages (6.6.4) | see Form A.4 and Form A.10 | P |
| 6.7 | Constructional requirements | | P |
| 6.7.1 | General | | N/A |
| 6.7.1 a) | Security of soldered wiring connections | | N/A |
| 6.7.1 b) | Screws securing removable covers are captive if their length affects isolation distances | | N/A |
| 6.7.1 c) | Accidental loosening | | N/A |
| | The following is not used for safety purposes: | | P |
| | 1) Materials which can be easily damaged (enamel etc) | | P |

| IEC 61010-031 | | | |
|---------------|--|---------------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| | 2) Non-impregnated hygroscopic materials | | P |
| 6.7.2 | ENCLOSURES of PROBE ASSEMBLIES with DOUBLE or REINFORCED INSULATION | | P |
| | ENCLOSURE which surrounds all metal parts | | P |
| | Small metal parts are separated from HAZARDOUS LIVE voltages by DOUBLE or REINFORCED INSULATION | No such part | N/A |
| | ENCLOSURES or parts made of insulating material fulfil requirements for DOUBLE or REINFORCED INSULATION. | see Form A.4 and Form A.9 | P |
| | Protection for metal ENCLOSURES or parts is provided by one of the following: | | N/A |
| | a) provision of an insulating coating or BARRIER on the inside of the ENCLOSURE | | N/A |
| | b) CLEARANCES and CREEPAGE DISTANCES cannot be reduced by loosening of parts or wires | | N/A |
| 6.7.3 | Corona and partial discharge | | N/A |
| | No corona or partial discharge while operating at maximum voltage | | N/A |
| 6.7.4 | Cable attachment | | P |
| | Withstand forces likely to be encountered | | P |
| 6.7.4.1 | Pull test | see Form A.11 | P |
| 6.7.4.2 | Flexing/pull test | see Form A.11 | P |
| 6.7.4.3 | Rotational flexing test | see Form A.11 | P |
| 6.7.5 | Insulation of a probe cable | | P |
| | Probe cable with a wear indicator provide DOUBLE or REINFORCED INSULATION when new, and at least BASIC INSULATION when the wear indicator is reached | Wear indicator employed | P |
| | PROBE CABLE without a wear indicator provide DOUBLE or REINFORCED INSULATION | | N/A |
| | Voltage test in acc. 6.6 (specify parts): | see Form A.10 | P |
| | - REINFORCED INSULATION: one unconditioned sample before cycling treatment | | P |
| | - BASIC INSULATION: contrasting colour became visible during the cycling treatment | | P |
| | - REINFORCED INSULATION: 250 cycles treatment without contrasting colour becoming visible. | | N/A |
| 7 | PROTECTION AGAINST MECHANICAL HAZARDS | | P |
| | Handling during normal use shall not lead to hazard | | P |

| IEC 61010-031 | | | |
|---------------|--|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| 8 | MECHANICAL RESISTANCE TO SHOCK AND IMPACT | | P |
| | Withstand shock and impact likely to occur in NORMAL USE | | P |
| 8.1 | Rigidity test | | P |
| | 20 N applied three times | | P |
| 8.2 | Drop test | | P |
| | Three samples dropped | | P |
| 8.3 | Impact swing test | | P |
| | Probe subjected to impact against a hardwood board | | P |
| | After the tests of 8.1 to 8.3: | | P |
| | Voltage tests in acc. to 6.6 | (see Form A.10) | P |
| | Inspections: | | P |
| 8a) | HAZARDOUS LIVE parts not accessible | | P |
| 8b) | ENCLOSURE shows no cracks (hazard) | | P |
| 8c) | CLEARANCES not less than their permitted values | (see Form A.9) | P |
| 8d) | BARRIERS not damaged or loosened | | P |
| 8e) | No damage which could cause spread of fire | | P |
| 9 | TEMPERATURE LIMITS AND PROTECTION AGAINST THE SPREAD OF FIRE | | P |
| 9.1 | General | | P |
| | Any heating does not cause a HAZARD in NORMAL CONDITION nor in SINGLE FAULT CONDITION | | P |
| | No spread of fire outside the PROBE ASSEMBLY | | P |
| | Easily touched surfaces not exceeding the following limits in NORMAL CONDITION : | | P |
| | - metal less than 55 °C | No such part | N/A |
| | - non-metallic less than 70 °C | | P |
| | - wires and cables less than 75 °C | | P |
| | Temperatures in SINGLE FAULT CONDITION less than 105 °C | | N/A |
| | Easily touched heated surfaces recognizable or marked with symbol 9 of table 1 (s. 5.2), if necessary for functional reasons | No such part | N/A |
| | Circuits separated by at least by BASIC INSULATION, if protection depends on separation of circuits | | N/A |
| 9.2 | Temperature tests | see Form A.12 | P |

| IEC 61010-031 | | | |
|---------------|---|-----------------------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| 10 | RESISTANCE TO HEAT | | P |
| 10.1 | Integrity of CLEARANCES and CREEPAGE DISTANCES | | P |
| | Requirements of 6.5 are met at an ambient temperature of 40 °C of maximum RATED ambient temperature (if higher) | see Form A.9 | P |
| 10.2 | Resistance to heat | | P |
| | Probe assemblies with non-metallic ENCLOSURES are resistant to elevated temperatures: | see Form A.13 | P |
| 11 | PROTECTION AGAINST HAZARDS FROM FLUIDS | | N/A |
| 11.1 | General | | N/A |
| | OPERATOR and surrounding area are protected against HAZARDS from fluids if PROBE ASSEMBLIES containing or intended to be used with fluids | No fluid employed | N/A |
| 11.2 | Cleaning | | N/A |
| | Cleaning procedure applied three times to the PROBE ASSEMBLY | | N/A |
| 11.3 | Specially protected PROBE ASSEMBLIES | | N/A |
| | Where the equipment is RATED or marked by the manufacturer the requirements of IEC 60529 are fulfilled | | N/A |
| | After the tests of 11.1 to 11.3: | | N/A |
| | Accessible parts do not exceed the limits of 6.3.1 | | N/A |
| | Voltage tests in acc. to 6.6 | | N/A |
| 12 | COMPONENTS | | P |
| 12.1 | General | | P |
| | Safety components operated within their specified RATINGS | see Table 3, probe body and cable | P |
| | Components approved by a recognized testing authority for conformity | see Table 3 | P |
| | Those components comply with one of the following : | | N/A |
| 12.1 a) | comply with all applicable safety requirements in relevant IEC standards | | N/A |
| | and subjected to the tests of this standard if necessary for application | | N/A |
| 12.1 b) | comply with all relevant requirements of this standard | | N/A |

| IEC 61010-031 | | | |
|---------------|--|-------------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| | and subjected to the tests of relevant IEC component standard if necessary for application | | N/A |
| 12.1 c) | comply with all relevant requirements of this standard only if there is no relevant IEC standard | | P |
| 12.2 | Fuses | | N/A |
| | Voltage RATING | No fuse | N/A |
| | Breaking capacity and current rating | | N/A |
| 12.3 | HIGH-INTEGRITY components | | N/A |
| | Positions of use | No such component | N/A |
| | Evaluated to IEC Publications | | N/A |
| | A single electronic device which employs electron conduction in a vacuum, gas or semiconductor is not used as HIGH-INTEGRITY component | | N/A |
| 12.3.1 | Resistors used in PROTECTIVE IMPEDANCE | | N/A |
| 12.3.1 a) | Withstand twice the dissipation at RATED voltage | | N/A |
| 12.3.1 b) | Withstand twice the RATED voltage for 1 s | | N/A |
| 12.3.1 c) | Distance across resistor or assembly: | | N/A |
| | fulfil requirements for DOUBLE or REINFORCED INSULATION | see Form A.9 | N/A |
| | If heating occurs at maximum working voltage, CLEARANCE complies with temperature corrected value | | N/A |
| 13 | Prevention of HAZARD from arc flash and short-circuits | | P |
| 13.1 | General | | P |
| | PROBE TIPS and crocodile clips are constructed to mitigate the risk of arc flash and short-circuits. | | P |
| 13.2 | Exposed conductive parts | | P |
| 13.2. a) | PROBE ASSEMBLIES RATED for CAT III or IV, the exposed conductive part of a PROBE TIP \leq 4 mm. | 3.80 mm | P |
| 13.2. b) | Special applications within CAT I where the energy levels not support arc flash or fire, the exposed conductive part of a PROBE TIP \leq 80 mm | | N/A |
| 13.2. c) | Other PROBE ASSEMBLIES, the exposed conductive part of a PROBE TIP \leq 19 mm. | | N/A |
| 13.2. d) | The outer surfaces of the jaws of crocodile or similar clips RATED for CAT II, III, or IV are not conductive. | | N/A |

| IEC 61010-031 | | | |
|---------------|---|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |
| | HAZARDOUS LIVE parts are not ACCESSIBLE when closed | | N/A |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| | | | | | |
|---|---|----------------|-------------|--------------|-----|
| 4.4.2 | TABLE: Summary of SINGLE FAULT CONDITIONS | | | Form A.1 | N/A |
| | | | | | |
| Subclause | Title | Does not apply | Carried out | Comments | |
| 4.4.2.1 | Equipment or parts for short-term or intermittent operation | | | | |
| 4.4.2.2 | Outputs of type B and type C PROBE ASSEMBLIES | | | | |
| 4.4.2.3 | Insulation between circuits and parts | | | | |
| 4.4.2.4 | Components of type B and type C PROBE ASSEMBLIES | | | see Form A.2 | |
| List below all SINGLE FAULT CONDITIONS not covered by 4.4.2.1 to 4.4.2.4: | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| Supplementary information: (see Form A.2 for details of tests) | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| 4.4 | TABLE: Testing in single FAULT CONDITION – Results | | | Form A.2 | N/A |
|-----------------|--|-------------------|-----------------|-------------------------------------|-------------|
| Test sub clause | Fault No. | Fault description | Td 4.4.3 (NOTE) | How was test terminated Comments | Meets 4.4.4 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |


NOTE Td = Test duration in h:min:s
Record voltage test on Form A.10 and temperature tests on Form A..12
Record in the comments column for each test whether carried out during or after SINGLE FAULT CONDITION.

Supplementary information:

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| | | | | | | |
|---|-------------------------------|----------------------------|------------------------|----------------------------|----------|---|
| 5.3 | TABLE: Durability of markings | | | | Form A.3 | P |
| Marking method (see NOTE) | | | | Agent | | |
| 1) | | | | A Water | | |
| 2) | | | | B Isopropyl alcohol | | |
| 3) | | | | C (specify agent) | | |
| 4) | | | | D (specify agent) | | |
| 5) | | | | E (specify agent) | | |
| | | | | | | |
| NOTE – Where applicable include print method, label material, ink or paint type, fixing method, adhesive and surface to which marking is fixed. | | | | | | |
| Marking location | | | | Marking method (see above) | | |
| Identification (5.1.2) | | | | Molded | | |
| Fuses (5.1.3) | | | | N/A | | |
| TERMINALS and operating devices (5.1.4) | | | | N/A | | |
| DOUBLE/REINFORCED equipment (5.1.5) | | | | Molded | | |
| Rating (5.1.6) | | | | Molded | | |
| Warning marking (5.2) | | | | Molded | | |
| | | | | | | |
| Method | Test agent | Remains legible Verdict | Label loose Verdict | Curled edges Verdict | Comments | |
| molded | B | Yes | Yes | Yes | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| Supplementary information: | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| | | | | | | | | | |
|---|-----------------|--|---|-----|--|--------|--------------------|--------------|----------|
| 6 | | TABLE: Protection against electric shock - Block diagram | | | | | | Form A.4 | |
| <div></div> | | | | | | | | | |
| POLLUTION DEGREE ... : 2 | | | Measurement category (overvoltage category).. : CAT IV 600 V CAT III 1000 V | | | | | | |
| Location or | Insulation type | Maximum working | CREEPAGE DISTANCE (NOTE 3) | | | | CLEARANCE (NOTE 3) | Test voltage | Comments |
| description | (NOTE 1) | voltage (NOTE 2) | PWB mm | CTI | Other mm | CTI | mm | (NOTE 2) V | |
| Probe tip to barrier | RI | CAT IV 600 V CAT III 1000 V | -- | -- | 31.5 | IIIa-b | 31.5 | 6880 | |
| NOTE 1 – Type of insulation: BI = BASIC INSULATION DI = DOUBLE INSULATION PI = PROTECTIVE IMPEDANCE RI = Reinforced INSULATION SI = Supplementary INSULATION | | NOTE 2 - Types of voltage Peak impulse test voltage (pulse) r.m.s. d.c. peak | | | NOTE 3 - MEASUREMENT CATEGORY (OVERVOLTAGE CATEGORIES) or POLLUTION DEGREES which differ from these should be shown under "Comments". | | | | |
| Supplementary Information: Limits: pollution degree 2, material group IIIa-b Cr=20.0 mm(RI), CL=14.3 mm(RI) | | | | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

[illegible]

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| | | | | | | | | | | | | | |
|---|--|-----------|-----------|-----------------------------|--------------|------------|------------|---|----|-----------|----|----|----------|
| 6.3.1 | TABLE: Values in NORMAL CONDITION (see NOTE 1) | | | | | | | Form A.6 | | | | | P |
| 6.1.1 | Exceptions | | | | | | | 11.1 General | | | | | |
| 6.3.1 | Values in NORMAL CONDITION | | | | | | | 11.2 Cleaning | | | | | |
| | | | | | | | | 11.3 Specially protected PROBE ASSEMBLIES | | | | | |
| Item (see Form A.5) | Voltage | | | Current | | | | Capacitance | | 10 s test | | | Comments |
| | V r.m.s. | V peak | V d.c. | Test circuit A1/A2/A3 | mA r.m.s. | mA peak | mA d.c. | μC | mJ | V | μC | mJ | |
| Probe body | 117.0 | 165.4 | -- | A1 | 0.15 | 0.48 | -- | -- | -- | -- | -- | -- | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| NOTE 1 – The requirements of 6.3.1 include drying out (if specified). | | | | | | | | | | | | | |
| Supplementary information: | | | | | | | | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| 6.3.2 | TABLE: Values in SINGLE FAULT CONDITION | | | | | | | | | | Form A.7 | N/A |
|---|--|-------------|-----------|-----------|-------------------------|---|-----------------------------|--------------|------------|------------|--------------|----------|
| Item (See Form A.4) | Sub clause and fault No. (see FormA.2) | Voltage | | | Transient (see NOTE) | | Current | | | | Capacitance | Comments |
| | | V r.m.s. | V peak | V d.c. | V | s | Test circuit A1/A2/A3 | mA r.m.s. | mA peak | mA d.c. | μF (NOTE) | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| NOTE – Transient voltages must be below the limits given from Figure 1 and the capacitance below the limits from figure 5 of IEC 61010-031. | | | | | | | | | | | | |
| Supplementary information: | | | | | | | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| | | | | |
|--|-----------------------------|----------|----------|-----|
| 6.4.6 | TABLE: PROTECTIVE IMPEDANCE | | Form A.8 | N/A |
| A high INTEGRITY single component | | | | |
| Component | | Location | Comments | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| A combination of components | | | | |
| Component | | Location | Comments | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| A combination of BASIC INSULATION and a current or voltage limiting device | | | | |
| Component | | Location | Comments | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| Supplementary information: | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result – Remark | Verdict |

| 6.5 | TABLE: CLEARANCES and CREEPAGE DISTANCES | | | | | | | | | | Form A.9 | P |
|--|---|-----------|---------|-------------------------|----------|-------|--------------|-------------------------------|-----------------------------------|-----------|-----------------|----------|
| 6.4 | Insulation requirements for protection against electric shock | | | | | | | | | | | P |
| 6.7.2 | ENCLOSURES of PROBE ASSEMBLIES with DOUBLE or REINFORCED INSULATION | | | | | | | | | | | P |
| 8 | Mechanical resistance to shock and impact | | | | | | | | | | | P |
| 10.1 | Integrity of CLEARANCES and CREEPAGE DISTANCES | | | | | | | | | | | P |
| Location (see Form A.4) | Measured (initial) | | Verdict | Mechanical tests (note) | | | | Test at max. RATED ambient | Measured after test (if required) | | Verdict | |
| | CREEPAGE DISTANCE | CLEARANCE | | Applied force | Rigidity | Drop | Impact swing | | CREEPAGE DISTANCE | CLEARANCE | | |
| | mm | mm | | N | (8.1) | (8.2) | (8.3) | (10.2) | mm | mm | | |
| Probe tip and barrier | 31.5 | 31.5 | P | 30N | 20N | 1 m | 0.37m | 70 | 31.5 | 31.5 | P | |
| NOTE – Refer to Form A.10 for voltage tests following the above tests. | | | | | | | | | | | | |
| Supplementary information: | | | | | | | | | | | | |

| IEC 61010-031 | | | | | | |
|--|---|--------------------|--|---------------------------------------|----------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict | | | |
| 6.6 | TABLE: Voltage tests | Form A.10 | P | | | |
| 4.4.4 | Conformity after application of fault conditions ¹ | | N/A | | | |
| 6.4 | Insulation requirements for protection against electric shock | | P | | | |
| 6.7.2 | ENCLOSURES of PROBE ASSEMBLIES with DOUBLE OR REINFORCED INSULATION | | P | | | |
| 6.7.5 | Insulation of a probe cable | | P | | | |
| 8 | Mechanical resistance to shock and impact | | P | | | |
| 11 | Protection against hazards from fluids | | N/A | | | |
| ¹ Record the fault, test or treatment applied before the voltage test | | | | | | |
| | Test site altitude | m | — | | | |
| | Test voltage correction factor (see Table 10)..... | | — | | | |
| Location or references from Forms A.2 and A.4 | Clause or sub-clause | Humidity Yes/No | Working voltage V | Test voltage r.m.s./peak/d.c. V | Comments | Verdict |
| Probe tip to probe body | 6.4 | No | CAT III 1000 V CAT IV 600 V | 6880 Vrms | -- | P |
| Probe tip to probe body | 6.7.2 | No | | 6880 Vrms | -- | P |
| Probe tip to probe body | 6.7.5 | No | | 4300 Vrms | -- | P |
| Probe tip to probe body | 8 | No | | 6880 Vrms | -- | P |
| Supplementary information: | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| 6.7.4 | TABLE: Cord anchorage of cable attachment | | | | | | Form A.11 | P |
|----------------------------|---|---------|------------------|---------|-----------------------|---------|-----------|---|
| Location | Pull N | Verdict | Flexing/ pull | Verdict | Rotational flexing | Verdict | Comment | |
| Cable to probe body | 36 | P | 8.1 | P | 500 | P | | |
| Cable to equipment | 36 | P | 8.1 | P | 500 | P | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| Supplementary information: | | | | | | | | |

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

[illegible]

| IEC 61010-031 | | | |
|---------------|--------------------|-----------------|---------|
| Clause | Requirement + Test | Result - Remark | Verdict |

| | | | | | | | |
|----------------------------|--|----------|-------|----------|------------------|---------|---|
| 10.2 | TABLE: Resistance to heat of non-metallic enclosures | | | | Form A.13 | | P |
| | Test method used: | | | | | — | |
| | Non operative treatment.....: | | [V] | | | | |
| | Empty ENCLOSURE.....: | | [] | | | | |
| | Operative treatment.....: | | [] | | | | |
| | Temperature during tests | | | | | — | |
| | ENCLOSURE samples tested were | | | | | — | |
| Description | | Material | | Comments | | Verdict | |
| Probe assembly | | PVC | | | | P | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | Voltage test (6.6) | | 6880 | V | r.m.s./peak/d.c. | r.m.s | |
| Supplementary information: | | | | | | | |

Probe assembly



Probe body



Connector to equipment



Wear indicator

