



CB TEST CERTIFICATE

Ref. Certificate No.

NL-23133

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Circuit-breakers for overcurrent protection		
Applicant:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Manufacturer:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Factory:	ZHEJIANG GACIA ELECTRICAL APPLIANCE CO.,LTD	545# Dongdajie, Baitawang Industrial Zone, Beibaixiang, Yueqing, Zhejiang, 325603	China
Rating and principal characteristics:	1P+N (N is not protected) Ue = 240 Vac, 50 / 60 Hz In = 6 A, 10 A, 16 A, 20 A, 25 A, 32 A, 40 A, Type C Ics = Icn = 6 kA safety distance "a" = 45 mm		
Trade mark (if any):	GACIA		
Model/Type reference:	PN8H, PN8HQ, PN8N, PN8NQ, PN8L, PN8LQ		
Additional information:	Energy limiting class 3 according EN 60898-1. This test certificate is based on CB test certificate NL-17849 dated on 2010-03-09. All tests were performed in 2010.		
Sample of product tested to be in conformity with IEC:	60898-1(ed.1);am1;am2		
Test Report Ref. No:	3301074.50, 3303233.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2012-05-15



DEKRA Certification is
former KEMA Quality