



Attestation of Conformity

No. 2017-025

Cables for use in construction works Reaction to fire class E_{ca}

Company
Z-Link

Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, PVC jacket

Product identification

U/UTP CAT5E 4P 24AWG PVC
Part no. 214111221

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendment A1:2015
- EN 13501-6:2014

Reaction to fire classification

Class E_{ca}

Technical report

DELTA-T600959-06, DANAK-19/17191

EC Cabling product ID

6124

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR).

Hørsholm, 15 January 2017

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

DELTA – a part of FORCE Technology

Venlighedsvej 4 Tel. +45 72 19 40 00
2970 Hørsholm Fax +45 72 19 40 01
Denmark www.madebydelta.com/cable