EFECTIS ERA AVRASYA

Notified Body Nr: 2184 AB-0556-T

ERA-23-008

01-23

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH EN 13501-6:2018

TOP ELECTRONIC COMPONENTS S.A.

IMPORTER: 66 Alkminis Str. 11853 Athens Greece

Tel.: +30-210-3428690 / 693 Fax.: +30-210-342869

E-mail: info@topelcom.gr

Product name H03VH-H - 2x0,75 mm² - (2,7-5,4) mm

Report no. ERA-23-008

Issue number 1/2

Date of issue 06.01.2023

This classification report consist of 5 pages and may only be used or reproduced in its entirety.

1. INTRODUCTION

This classification report defines the classification assigned to " $H03VH-H - 2x0,75 \text{ mm}^2 - (2,7-5,4) \text{ mm}$ " in accordance with the procedures given in EN 13501-6:2018.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. General:

 $H03VH-H - 2x0,75 \text{ } mm^2 - (2,7-5,4) \text{ } mm$ is defined as a "type of classified product". Its classification is valid for the following end use application:

EN 50575:2014/A1:2016 - Power, control and communication cables - Cables for general applications in construction works subject to reaction to fire requirements

2.2. Description:

 $H03VH-H - 2x0,75 \text{ } mm^2 - (2,7-5,4) \text{ } mm$ is fully described in the test reports in support of the classification listed in clause 3.1.

Tested product types:

Product name	Nominal voltage [V]	Cross section area [mm²]	External overall diameter of minor axis [mm]	External overall diameter of major axis [mm]	Cable structure
H03VH-H Single core unsheathed Non-circular duplex Power cable	300/300	2x0,75	2,7	5,4	PVC insulation, stranded copper wire conductor (Class 5)

3. REPORTS AND RESULTS IN SUPPORT OF CLASSIFICATION

3.1. Reports

Name of laboratory	Name of sponsor	Report ref. no.	Test method and date Field of application rules and date
			EN 60332-1-2:2004
EFECTIS	TOP ELECTRONIC COMPONENTS S.A.	FTST23011	EN 60332-1-2:2004/A1:2015
			EN 60332-1-2:2004/A11:2016

3.2. Results

			Result		
Test method	Parameter	Number of test	Continuous parameter mean (m)	Compliance parameters	
EN 60332-1-2 Flame exposition: 60 s	H (mm)	1	118	(-)	

^{(-):} not applicable

The table below shows the worst results of the classification parameters:

Test method	Parameter	Safety margin	Classification result	Compliance parameters	
EN 60332-1-2	H (mm)	(-)	118	≤ 425 (Eca)	

^{(-):} not applicable

4. CLASSIFICATION AND FIELD OF APPLICATION

4.1. Reference of classification

This classification has been carried out in accordance with the clauses 9.3 of EN 13501-6:2018.

4.2. Classification

H03VH-H - 2x0,75 mm² - (2,7-5,4) mm in relation to its reaction to fire behaviour is classified:

 E_{ca}

The additional classification in relation to smoke production is:

not classified

The additional classification in relation to flaming droplets / particles is:

not classified

The additional classification in relation to acidity is:

not classified

The format of the reaction to fire classification for H03VH-H - 2x0,75 mm² - (2,7-5,4) mm is:

Fire behaviour		Smoke production			Flaming droplets			Acidity	
E _{ca}	-	S	not classified	,	d	not classified	,	a	not classified

Reaction to fire classification: Eca

4.3. Field of application

This classification is valid for the following product:

Parameters as determined in the extended application process according to $\it CLC/TS$ 50576:2016

Cable	H03VH-H - 2x0,75 mm²			
Cable family specified in CLC/TS 50576:2016	Single core unsheathed Power cable			
External overall diameter of minor axis [mm]	2,7			
External overall diameter of major axis [mm]	5,4			
Colour	Indifferent			
Shape	Non-circular duplex			
Flexibility	Flexible			
Manufacturing plant	Article 2.2			
Cable structure				
PVC insulation				
Stranded copper wire conductor (Class 5)				

The classification is valid for all end use applications.

5. LIMITATION

5.1. Restrictions

This classification report is valid provided that the technical specifications of product are within the limits in accordance with the field of application clause 4.3.

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the 305/2011/EU Construction Products Regulation.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.