



Certificate: 70094625

Master Contract: 268232

Project: 70094625

Date Issued: 2016-10-26

	5, 6, 9, 12, 24, 36, 48, 60, 110 Vdc						
--	--------------------------------------------	--	--	--	--	--	--

Relay, open type, Cat. No. 36, followed by .02 or .04, maybe followed by T, maybe followed by S, maybe followed by A, maybe followed by P, maybe followed by H, maybe followed by S, maybe followed by L, followed by numbers from 5VDC, 6VDC, 12VDC, 24VDC, 48VDC, 60VDC, 110VDC, 6VAC, 12VAC, 24VAC, 48VAC, 110/120VAC, 115VAC, 230VAC or 220/240VAC. Ratings as specified in below table.

Cat. No.	Coil Voltage	Contact Arrangement	Contact Rating		Electrical Operating cycles	Load Type	Surrounding Air Temperature (°C)
			Voltage	Current (A)			
36.02 36.02A 36.04 36.04A	6, 12, 24, 48, 110/120, 220/240 Vac (50/60 Hz); 5, 6, 12, 24, 48, 60, 110 Vdc	2, 3 or 4 Form C	250 Vac / 30 Vdc	5	10,000	General Use & Resistive	70
36.02T 36.02TA		2, 3 or 4 Form A (NO&NC)		10			

Accessory Relay Sockets, Model Nos. AS760, AS770, rated 400 Vac, 10 A and RT702-B, rated 300 Vac, 12 A and RT704-B, rated 300 Vac, 10 A. For use with above relays, maximum surrounding ambient temperature 85 °C.

Conditions of Acceptability:

1. The terminals are to be factory wired only and the suitability of the connection (including spacings between factory connectors) shall be determined in the end use application.
2. Spacing from the exposed live metal parts to the enclosure walls shall be in accordance with the requirements of the overall equipment.
3. These devices shall be mounted in the intended manner in enclosure, having adequate strength, thickness and with acceptable spacings being provided.
4. These devices have not been evaluated for making and breaking a load. Relays shall therefore not be installed or removed under load.

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 14-13 - Industrial control equipment
- UL 508, 17th Edition - Industrial control equipment



Certificate: 70094625

Project: 70094625

Master Contract: 268232

Date Issued: 2016-10-26



Supplement to Certificate of Compliance

Certificate: 70094625

Master Contract: 268232

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70094625	2016-10-26	Original cCSAus Certification of: - Relay, open type, Cat. No. 36.02T, 36.02TA, 36.04, 36.04A, 90.2, 90.2A, 90.3, 90.3A. - Accessory Relay Socket, open type, Cat No. AS760, AS770, RT702-B, RT704-B. Based on Acceptance of UL Test Data in UL File E162825, Vol. 1, Sec. 5, dated 2012-12-10 and UL File E478927, Vol. 1, Sec. 1, dated 2015-10-30.