File E179745 Project 08CA04625

August 1, 2008

REPORT

ON

COMPONENT - INDUSTRIAL CONTROL SWITCHES

Dongguan Sanyou Electrical Appliances Co., Ltd.
Dongguan, Guangdong, China

Copyright  $\,$  © 2008 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report provided it is reproduced in its entirety.

Underwriters Laboratories Inc. authorizes the above named company to reproduce that portion of this Report consisting of this Cover Page through Page 3.

File E179745 Vol. 1

Vol. 1 Sec. 21 and Report

Page 2

Issued: 2008-08-01

## NOMENCLATURE:

- I. Series designation: DSY2Y
- II. Protective Construction
  S Sealed type
  SH Sealed type washable
- III. Number of Poles:
   2 poles
- IV. Coil Voltage:

  03 3 Vdc

  05 5 Vdc

  06 6 Vdc

  09 9 Vdc

  12 12 Vdc

  15 15 Vdc

  24 24 Vdc
- V. Coil Sensitivity: D - 0.36 W

48 - 48 Vdc

H - 0.15 W

L - 0.20 W

VI. Insulation System:

Nil - Standard Type

B - Class B (130 C)

F - Class F (155 C)

Note - Models with 48 Vdc coils are only provided with either class B or F insulation systems.

VII. Special Parameter:

Nil - Standard Type

Letters and/or Numbers - Special marking designations

File E179745 Vol. 1 Sec. 21 Page 3 Issued: 2008-08-01 and Report

ENGINEERING CONSIDERATIONS (Not for Field Representative's Use)

Special Consideration - The following items are considerations that were used when evaluating this product.

USR - Indicated evaluation to UL 508, Seventeenth Edition, the Standard for Industrial Control Equipment

CNR - Indicated evaluation to CSA 22.2 No. 14-05, the Standard for Industrial Control Equipment for Use in Ordinary Locations.

Conditions of Acceptability -

- 1. These devices are intended to be mounted in business and office equipment.
- 2. These devices shall be mounted in an appropriate enclosure.
- 3. If mounted in an environment where the ambient temperature exceeds  $85^{\circ}$ C, then consideration should be given to repeating the temperature test.
- 4. The Dust Cover has not been evaluated as an insulating barrier and should be considered in the end-use application with regards to spacing requirements to uninsulated live parts.
- 5. The spacings from exposed live-metal parts to the enclosure walls shall be in accordance with the requirements of the end-product.