



Ref. Certif. No.

HU-002442

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electromechanical contactor for household and similar purposes

Name and address of the applicant

MAXGE Electric Technology Co., Ltd
No.299, East Changhong Road, Deqing Economic Zone,
Wukang, Deqing, Zhejiang 313200, P.R. China

Name and address of the manufacturer

MAXGE Electric Technology Co., Ltd
No.299, East Changhong Road, Deqing Economic Zone,
Wukang, Deqing, Zhejiang 313200, P.R. China

Name and address of the factory

MAXGE Electric Technology Co., Ltd
No.299, East Changhong Road, Deqing Economic Zone,
Wukang, Deqing, Zhejiang 313200, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

AC-7a, Ue= AC 250V(1P, 2P); AC 400V(3P, 4P); 50/60Hz;
Ie: 16A for EPC1-16-x, EPC1-16-xM,
Ie: 20A for EPC1-20-x, EPC1-20-xM,
Ie: 25A for EPC1-25-x, EPC1-25-xM;
AC-7b, Ue= AC 250V(1P, 2P); AC 400V(3P, 4P); 50/60Hz;
Ie: 6A for EPC1-16-x, EPC1-16-xM,
Ie: 7A for EPC1-20-x, EPC1-20-xM,
Ie: 9A for EPC1-25-x, EPC1-25-xM;
Ith: 25A; Ui: 500V; Uimp: 4,0kV;
Us: AC 24V; 110V; 220-240V, 50/60Hz
(See Test Report for further ratings)

Trademark (if any)

MAXGE

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EPC1-16-x; EPC1-20-x; EPC1-25-x;
EPC1-16-xM; EPC1-20-xM; EPC1-25-xM
/x=10,20,02,11,30,22,31,40/
(See Test Report for type nomenclature)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 61095:2009

As shown in the Test Report Ref. No. which forms part of this Certificate

1C182019

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-01-15

Signature:

Gabor Kassai

