

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage switchgear and controlgear - Part 3:
Switch-disconnector

Name and address of the applicant

MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Deqing Economic zone,
Wukang, Deqing, 313200, Zhejiang China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue= 240V~ (1P), 415V~ (2P, 3P, 4P)
In= 16, 25, 32, 40, 63, 80, 100, 125A
Icw= 12Ie, 1s Icm= 20Ie Cat. AC-22A

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

SGI-R, EPI-R

Additional information (if necessary may also be
reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

220702378SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 14 November, 2022



Signature:


Quan Li