



Independent SAFETY & EMC Lab.

SHENZHEN EMTEK CO.,LTD  
Bldg. 69,Majialong Industry Zone,Nanshan District,  
Shenzhen,Guangdong, 518052 P.R. China  
Tel:+86-755-26954280 Fax:+86-755-26954282  
www.emcsafety.com

# Declaration of Conformity

NO.: E0605606S

The following product has been tested by us with the listed standards and found in conformity with the European directive LVD 73/23/EEC amended by 93/68/EEC. It is possible to use CE marking to demonstrate the conformity with this LVD Directive.

**Applicant** : DIANXING ELECTRICAL APPLIANCE  
INDUSTRY CO., LTD.

**Address** : Dianxing Industrial Building, Anle Development Zone,  
Dongfeng Town, Zhongshan, Guangdong, China

**Manufacturer** : DIANXING ELECTRICAL APPLIANCE  
INDUSTRY CO., LTD.

**Address** : Dianxing Industrial Building, Anle Development Zone,  
Dongfeng Town, Zhongshan, Guangdong, China

**EUT** : Automatic Voltage Regulator

**M/N** : TVR-8000VA, TVR-10KVA

**Technical Data** : Input: 150-260V~, 50Hz; Output: 230 V~/50Hz;  
Power: 8000W for model TVR-8000VA, 10KW for  
model TVR-10KVA

Test Standards:	
EN 61558-1:1997; EN 61558-2-1:1997;	Part 1: Safety of power transformers, power supply units and similar devices - General requirements and tests Part 2: Safety of power transformers, power supply units and similar - Particular requirements for separating transformers for general use
EN 60076-1: 1997; EN 60076-2:1997; EN 60076-3:2001	Part 1: Power transformers – General Part 2: Power transformers – Temperature rise Part 3: Power transformers – Insulation levels, dielectric tests and external clearances in air



(Manager)

May 15, 2006

The test report was carried out from the submitted type samples of a product in conformity with the specification of the respective standards. The certificate holder has the right to fix the CE-mark for LVD directive on the product complying with the inspection samples.