

TEST CERTIFICATE

Standart : BS 6004

Customer : TOP ELECTRONIC COMPONENTS SA

Type : 2x1.5+1

Order No : 2016/1064

Voltage : 300/500 V

Packing List No : 2016/01072

Designation: PVC FLAT

Date : November/2016

Drum No : KRT-100 /4086

Palet No

Length (m) : 8700

01.02.2016 71 F 08 Rev.5

TESTS	MEASURED VALUES					REQUIREMENTS
	Core1	Core2				
Conductor resistance at 20 °C	11.92	11.91				max. 12.10 ohm/km BS EN 60228
Circuit Protective Conductor Resistance at 20 °C	17.80					max. 18.10 ohm/km BS EN 60228
Voltage test (a.c.)	OK	OK				2 kV 5 minutes BS EN 50395
Ageing test for Insulation	PASS					BS 7655-1.3 & BS 7655-4.2 BS EN 50363-3
Compatibility test for Insulation & Sheath	PASS					BS 6004 ANNEX D BS EN 60811- 401, 501
Test under fire conditions						
Flame propagation test on single cable	PASS					BS EN 60332-1-2

No signatory approval is necessary since this test certificate has been prepared on electronic media

"PASS" means the measured value conforms the spec value (Type test conducted according to F 25)

"OK" means the measured value conforms the spec value (Routine test conducted according to F 100)

Our Products have " BASEC Product Licence "

BASEC Licence No : 097

This report is kept in archive for ten years.